

Intertek Legal Entity: Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Address: Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD, Guangzhou, China 510663 Telephone/Fax: 86-20-8213 9688/86-20-3205 7538

Test Verification of Conformity

On the basis of the referenced test report(s), sample(s) of the below product have been found to comply with the harmonized standards and Directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product.

Once all product relevant CE mark directives are verified in compliance, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to product identical to the test sample(s) if the product complies with all relevant CE mark Directives requirements.

Applicant Name & Address:

Jiangsu Aifuxi New Building Material Stock Co., Ltd

Tunnan Village, Tongli Town, Wujiang District, Suzhou City, China

Product Description: Ratings & Principle

Fiber Cement Board Reaction to fire Class A1

Characteristics:

Weather resistance: Category A

Bending strength (wet condition): Class 3 (20mm) and Class 4 (8mm)

Method of installation: Large size sheet

Dimensional tolerance: Level I

Models:

8mm, 9mm, 10mm, 12mm, 15mm, 18mm, 20mm

Brand Name:

Relevant Standards/ **Regulations / Directives:** EN 12467: 2012+A1:2016 Fibre-cement flat sheets —

Product specification and test methods

Construction Products Regulation (CPR) No.305/2011

Verification Issuing Office:

Same as Legal Entity **Date of Tests:**

March 3, 2016 to August 22, 2016

Test Report Number(s):

160303096GZU-001 dated on August 26, 2016

NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

NOTE 2: Reaction to fire was tested and assessed by Notified Body No. 1390.

Signature

Name: Jeff Deng

Position: Assistant Manager

Date: 26-08-2016

CE